

Annex

Date 2007-05-05	Document IEC 61499-1: 2005
--------------------	-------------------------------

National Committee	Clause/ Subclause	Paragraph Figure/ Table	Type of comment (General/ Technical/Editorial)	COMMENTS	Proposed change	OBSERVATIONS OF THE SECRETARIAT on each comment submitted
TC65/WG6	5.1	Figure 9	Technical	EI and EO variables are no longer used.	Change to "Event Inputs" and "Event Outputs"	
TC65/WG6	5.2.1.1	Item 3	Editorial	<i>input variables</i> should be <i>output variables</i>	Change <i>input</i> to <i>output</i> .	Received 2007-02-09
TC65/WG6	5.2.1.1	NOTE 1	Editorial	Wrong Annex is referenced.	Change "Annex G" to "Annex F"	
TC65/WG6	5.2.1.2	Para 2	Editorial	Wrong Annex is referenced.	Change "Annex G" to "Annex F"	
TC65/WG6	5.2.1.3	NOTE 1	Editorial	Wrong Annex is referenced.	Change "Annex G" to "Annex F"	
TC65/WG6	5.2.1.4	Item h	Technical	EI and EO variables are no longer used.	Change to "Each EC transition shall have an associated transition condition, expressed in the syntax defined for the non-terminal <code>ec_transition_condition</code> in Annex B.2.1."	Received 2007-02-09
TC65/WG6	5.4.1	Para 1	Editorial	Wrong subclause is referenced.	Change "5.2.1" to "5.3.1"	
TC65/WG6	6.3.3	Figure 24	Technical	RESET condition is not a value of the CMD input.	Define RESET in text.	Received 2007-02-09
TC65/WG6	Annex A	Table A.1	Technical	NULL state is unnecessary since CU input is not latched.	Delete NULL state and associated transitions.	Received 2007-05-05
TC65/WG6	Annex F	E_CTU	Technical	Declaration of E_CTU (#18) is not consistent with Table A.1.	Make E_CTU entry consistent with Table A.1	Received 2007-03-28